



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 3 TO PROJECT NO. #45060

**Repair/Replace Roof
DOT Region 1, Waterford
182 Davis Avenue
Waterford, NY 12188**

August 21, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

DRAWINGS

1. Drawing No. A-503:
 - a. ROOF HATCH DETAIL 1/ A-503: Change “PROVIDE GWB PARTITION FROM SLAB TO UNDERSIDE OF STEEL BEAM; 6” METAL STUDS AT 16” O.C. AND 5/8” GWB BOTH SIDES WITH BLOCKING AT LADDER SUPPORTS.” to “PROVIDE GWB PARTITION FROM SLAB TO UNDERSIDE OF STEEL BEAM, APPROXIMATELY 12’-6” HIGH; 6” METAL STUDS AT 16” O.C. AND 5/8” GWB BOTH SIDES WITH BLOCKING AT LADDER SUPPORTS. GWB PARTITION TO BE 8’-0” IN LENGTH, EXTENDING FROM AND PERPENDICULAR TO EXISTING WALL WEST OF THE OPENING.”

END OF ADDENDUM

Margaret F. Larkin
Acting Executive Director