



DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 2 TO PROJECT NO. 45184

**CONSTRUCTION, HVAC, PLUMBING & ELECTRIC WORK
REHABILITATE SHOWERS, DORM BUILDINGS 3-7, 17 & 18
WYOMING CORRECTIONAL FACILITY
3203 DUNBAR ROAD
ATTICA, NY**

August 2, 2016

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION CONTRACT

DRAWINGS

1. Assume 8' ceiling heights in work areas of all buildings on all drawings.
2. Drawing No. A-102:
 - a. The 4 bay sinks are at ADA height but the mirror and sink fitting is only ADA where designated by symbol.

PLUMBING CONTRACT

DRAWINGS

1. Drawing No. P-201:
 - a. Add size 'A' water hammer arrestors to detail 4 on the CW and DHW lines in a similar location to the water hammer arrestors in detail 3.
2. Drawing No. P-102:
 - a. Add size 'A' water hammer arrestors on the CW lines and size 'B' water hammer arrestors on the DHW lines at the end of the shower branch piping in detail 1 (typical of 4 locations).

HVAC CONTRACT

SPECIFICATIONS

1. Spec. No. 233418-2.01:
 - a. Add section 2.01-E for the sequence of operations for the fans. The sequence shall be that the fans are manually operated and that the damper is open when the fan is on and closed when the fan is off.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction