



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. M2977**

**PLUMBING WORK  
REPLACE WATER LINE AT POWER HOUSE  
CLINTON CORRECTIONAL FACILITY  
ROUTE 374  
COOK STREET  
DANNEMORA, NEW YORK**

November 14, 2011

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**THE INTENT OF THIS ADDENDUM IS TO CLARIFY THE EXTENT OF THE HDPE FOR THE 6 INCH WATER LINES IN BUILDINGS 22 & 32**

**DRAWINGS**

1. Drawing No. P-103:
  - a. DETAIL 2-DOMESTIC WATER SCHEMATIC: All new 6" water pipe is HDPE.
  
2. Drawing No. P-104
  - a. DETAIL 3-DOMESTIC WATER SCHEMATIC: All new 6" water pipe is HDPE.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design