



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT Q1479

CONSTRUCTION WORK AND ELECTRICAL WORK

**UPGRADE ELECTRICAL AND PROVIDE WALLS AND CEILINGS
BUILDING NO. 23
CLINTON CORRECTIONAL FACILITY
ROUTE 374, COOK STREET
DANNEMORA, NY**

October 27, 2011

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

FOR THE CONSTRUCTION WORK CONTRACT (Q1479-C):

All metal stud partitions indicated on the Contract Drawings shall have metal studs and track provided by the Contractor in sizes and quantities required to complete the work. Studs shall be 3-5/8" x 18ga with matching track. The 24' of 3-5/8" stud material shown on the "Bill of Materials to be Furnished by the Facility" will not be utilized in this Project.

All gypsum board shall be 4'x8'x5/8" impact resistant board as indicated on the "Bill of Materials to be Furnished by the Facility". As noted in Addendum No. 1, contractor shall supplement the furnished material with additional quantities as required to complete the work.

The 128 sq. ft. of 1/2" Mold Tough gypsum board shown on the "Bill of Materials to be Furnished by the Facility" will not be used in this Project.

Deep Leg Deflection Track, specified in Section 092116 Article 2.01 will not be used in this Project.

Flattened Expanded Metal Mesh specified in Section 092116 Article 2.05 is used for the infill of abandoned electrical boxes. This work is part of the Electrical Work Contract so this material is not required for the Construction Work Contract.

Unfaced Batt Insulation shall be (Basis of Design) Johns Manville Unfaced Formaldehyde Free Thermal and Acoustical Insulation, ASTM C665, Unfaced, Type 1, R-13, or approved equal.

Metal Collar Trim shall be (Basis of Design) chrome plated, solid metal split ring pipe escutcheon for use on ceilings, as manufactured by DBHL, or approved equal.

There is a conflict in joist size and gauge between Detail 2/A-102 and specification section 092116. The joists shall be per Detail 2/A-102 (18ga).

The manufacturer of ceiling joist material Furnished by the Facility cannot be ascertained at this time. For bidding purposes assume material is manufactured by Marinoware Cold Formed Systems.

FOR THE ELECTRICAL WORK CONTRACT (Q1479-E):

For the Flattened Expanded Metal Mesh specified for infill of electrical boxes on Detail 4/E-401, product specification shall be as follows: Flattened Expanded Metal Mesh: ASTM F 1267, Type II, Class 1, grade as selected by fabricator; 13 gage, 1/2 inch carbon sheet steel, diamond style.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design