



---

---

**ADDENDUM NO. 5 TO PROJECT NO. Q1537**

**REHABILITATE 2ND FLOOR LOCKER ROOMS  
STATE ARMORY  
1700 PARKWAY EAST  
UTICA, NEW YORK 13501**

October 12, 2012

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION WORK SPECIFICATIONS**

1. Section 092116, Gypsum Board Systems

**REPLACE** article 2.02(B) with the following:

- “B. FRP Laminated Gypsum Board: Type X 5/8 inch Fire Resistant Gypsum Board laminated with finished FRP overlay. Laminated product shall meet “Class A” interior wall and finish classification.
1. Basis of Design Product:
    - a. NuFiber Wall Panels by Nudo Products, Inc., 1500 Taylor Ave., Springfield, IL 62703, (800) 826-4132, [www.nudo.com](http://www.nudo.com)
  2. Texture & Finish: Pebble type finish, color selected from manufacturer standard color ranges (full range included in the bid).
  3. Accessories: Manufacturer recommended vinyl trim pieces, in shapes and profiles to accommodate required wall geometries.
  4. Fasteners: Stainless steel k-lath type fasteners spaced per manufactures recommendations.”

2. Section 096723, Epoxy Resin Flooring

**MODIFY** article 1.02(A) to read:

- “A. Type EC Flooring and Base: Epoxy floor coatings and base not less than 32 mils thickness, composed of an epoxy resin matrix and mineral filler aggregate with lightly ground and sealed finish.”

**REPLACE** references to “¼ inch thick coating” in article 3.03(E.1) with “32 mils”  
**DELETE** references to flooring type “ET” in article 3.03(E.3 & E.6)

**ADDENDUM NO. 5 TO PROJECT NO. Q1537 – C, H, P, E  
CONSTRUCTION WORK DRAWINGS**

1. Drawing A601 – Finish Schedule, Door Schedule, Door & Frame Details

Room & Finish Schedule

**ADD** the following to the General Remarks for Spaces 130, 132 & 234:

“Continue floor coating to bottom riser, 1<sup>st</sup> Floor, including landings and treads.”

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design