



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 4 TO PROJECT NO. Q1591**

**CONSTRUCTION WORK, ELECTRICAL WORK  
REPLACE DOORS  
ARMY AVIATION SUPPORT FACILITY #2  
76 PATRIOT WAY  
ROCHESTER, NEW YORK 14624**

September 22, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION WORK SPECIFICATIONS**

1. SECTION 083416, "HANGAR DOOR", Page 083416-2, Article 1.04, A: change the following sentence "All door components shall be designed to withstand both the highest positive and negative 'components and cladding' or 'main wind force resisting members' pressures as applicable." to "With the exception of items listed under Page 083416-5, Article 2.03, Doors, Paragraph A, all door components shall be designed to withstand both the highest positive and negative 'components and cladding' or 'main wind force resisting members' pressures as applicable."
2. SECTION 083416, "HANGAR DOOR", Page 083416-5, Article 2.03, A, in the third sentence, replace 28 psf with 25 psf.

**ELECTRICAL WORK SPECIFICATIONS**

3. SECTION 083416 "HANGAR DOOR", Page 083416-7, Article 2.04, F. 2, Delete in its entirety

**END OF ADDENDUM**

Margaret F. Larkin  
Executive Director