



Office of General Services

DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 1 TO PROJECT NO. Q1725 CONSTRUCTION WORK DEMOLISH BUILDING 50 ROCHESTER PSYCHIATRIC CENTER 1111 ELMWOOD AVENUE ROCHESTER, NY 14620

November 21, 2017

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. SECTION 024116-3.02 E: DELETE "and remove on-grade slabs".

CONTRACT DRAWINGS

1. Drawing C-101, Demolition Note1, Add the following two paragraphs:

"No information is available as to whether the steam line to the building exists or if it was previously abandoned. For bidding purposes, assume it's an 8-inch diameter steam line that enters the building in the basement. The line will need to be capped prior to filling the area with selected fill. If no line is found entering the basement, then it can be assumed the line was previously abandoned.

All utility's, with the possible exception of the steam line, are believed to have been disconnected. Contractor shall confirm prior to demolition."

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction