



DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 3 TO PROJECT NO. Q1916

**CONSTRUCTION AND ELECTRICAL WORK
REPLACE PERIMETER DETECTION & CAMERA SYSTEMS
SHAWANGUNK CORRECTIONAL FACILITY
200 QUICK ROAD
WALLKILL, NY**

March 13, 2026

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.
--

ELECTRICAL WORK SPECIFICATIONS

1. SECTION 281604 - MICROWAVE DETECTION SYSTEM, Paragraph 2.2 A.2a: Change subparagraph to read:

 “a. Voltage: 10.5 – 28 VDC”

2. SECTION 281604 - MICROWAVE DETECTION SYSTEM, Paragraph 2.2 A.5: Change subparagraph to read:

 “5. Central 28 volt nominal DC power supply backed by UPS power for powering microwave dual technology sensors.”

END OF ADDENDUM

Brady M. Sherlock, P.E.
Director, Division of Design
Design & Construction